

Noise Level Compliance Report APPENDIX

for the

Lake Winds Energy Park – Spring 2016 Noise Level Measurements

Mason County, Michigan

August 2016



Prepared for:

Mason County Michigan
Scottville, Michigan

Prepared by:

Hankard Environmental, Inc.
Verona, Wisconsin



APPENDIX A

NOISE MEASUREMENT EQUIPMENT CALIBRATION CERTIFICATES



1575 State Route 96, Victor NY 14564



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

Brüel & Kjær Hand-held Analyzer

for
Model No.: 2250

Serial No.: 2676058


Company: Hankard Environmental Inc.

ID No.: XXXX

The procedure from IEC 61672-3-2013 were used to perform the periodic test. (Test limits are from IEC 61672-1-2013)
Instrument submitted for testing has successfully completed the Class 1 periodic test of IEC 61672-3-2013 listed below.
Also meets the requirements of ANSI/ASA S1.4 - 2014 / Part 3.
Fulfills 1/1-Octave and 1/3-Octave Filter ANSI/ASA S1.11 -1-2004 and IEC61260-1 : 2014 requirements.

Absolute Acoustical Sensitivity Level, IEC 61672 - 3 (9)	Pass
Electrical Inherent Noise Level, Freq. Weig. Lin, IEC 61672-3 (10)	Pass
Determining Electrical Level for 1V at 1kHz	Pass
Frequency Response measured with Electrical Signal, Freq. Weig. A with HP filter, IEC 61672 Class 1 (12)	Pass
Frequency Response measured with Electrical Signal, Freq. Weig. C with HP filter, IEC 61672 Class 1 (12)	Pass
Frequency Response measured with Electrical Signal, Freq. Weig. Z with HP filter, IEC 61672 Class 1 (12)	Pass
Frequency Weightings at A - Weighting 1kHz, IEC 61672-3 (13)	Pass
Frequency Weightings at C - Weighting 1kHz, IEC 61672-3 (13)	Pass
Frequency Weightings at Z - Weighting 1kHz, IEC 61672-3 (13)	Pass
Linearity Range at 1kHz, IEC61672 - 3 (14)	Pass
Range Level at 1kHz, IEC61672 - 3 (15)	Pass
Time Weighting Response to Single Burst, 4kHz, 200ms, F Class 1, IEC61672 - 3 (16)	Pass
Time Weighting Response to Single Burst, 4kHz, 2ms, F Class 1, IEC61672 - 3 (16)	Pass
Time Weighting Response to Single Burst, 4kHz, 0.25ms, F Class 1, IEC61672 - 3 (16)	Pass
Time Weighting Response to Single Burst, 4kHz, 200ms, S Class 1, IEC61672 - 3 (16)	Pass
Time Weighting Response to Single Burst, 4kHz, 2ms, S Class 1, IEC61672 - 3 (16)	Pass
Peak C Level 8kHz Sine IEC 61672 - 3 Class 1 (17)	Pass
Peak C Level 500Hz Positive Pulse IEC 61672 - 3 Class 1 (17)	Pass
Peak C Level 500Hz Negative Pulse IEC 61672 - 3 Class 1 (17)	Pass
Overload Indication IEC 61672 - 3 (18)	Pass
Octave and 1/3 Octave level IEC 61260 - 5.3	Pass

Calibrated on WCCL system type 9700

Measurements performed by: **Kent Zeng**

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 10382250B&K



1575 State Route 96, Victor NY 14564



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

for

Brüel & Kjær Hand-held Analyzer

Model No.: 2250

Serial No.: 2676018


Company: Hankard Environmental Inc.

ID No.: XXXX

The procedure from IEC 61672-3-2013 were used to perform the periodic test. (Test limits are from IEC 61672-1-2013)
Instrument submitted for testing has successfully completed the Class 1 periodic test of IEC 61672-3-2013 listed below.
Also meets the requirements of ANSI/ASA S1.4 - 2014 / Part 3.
Fulfills 1/1-Octave and 1/3-Octave Filter ANSI/ASA S1.11 -1-2004 and IEC61260-1 : 2014 requirements.

Absolute Acoustical Sensitivity Level, IEC 61672 - 3 (9)	Pass
Electrical Inherent Noise Level, Freq. Weig. Lin, IEC 61672-3 (10)	Pass
Determining Electrical Level for 1V at 1kHz	Pass
Frequency Response measured with Electrical Signal, Freq. Weig. A with HP filter, IEC 61672 Class 1 (12)	Pass
Frequency Response measured with Electrical Signal, Freq. Weig. C with HP filter, IEC 61672 Class 1 (12)	Pass
Frequency Response measured with Electrical Signal, Freq. Weig. Z with HP filter, IEC 61672 Class 1 (12)	Pass
Frequency Weightings at A - Weighting 1kHz, IEC 61672-3 (13)	Pass
Frequency Weightings at C - Weighting 1kHz, IEC 61672-3 (13)	Pass
Frequency Weightings at Z - Weighting 1kHz, IEC 61672-3 (13)	Pass
Linearity Range at 1kHz, IEC61672 - 3 (14)	Pass
Range Level at 1kHz, IEC61672 - 3 (15)	Pass
Time Weighting Response to Single Burst, 4kHz, 200ms, F Class 1, IEC61672 - 3 (16)	Pass
Time Weighting Response to Single Burst, 4kHz, 2ms, F Class 1, IEC61672 - 3 (16)	Pass
Time Weighting Response to Single Burst, 4kHz, 0.25ms, F Class 1, IEC61672 - 3 (16)	Pass
Time Weighting Response to Single Burst, 4kHz, 200ms, S Class 1, IEC61672 - 3 (16)	Pass
Time Weighting Response to Single Burst, 4kHz, 2ms, S Class 1, IEC61672 - 3 (16)	Pass
Peak C Level 8kHz Sine IEC 61672 - 3 Class 1 (17)	Pass
Peak C Level 500Hz Positive Pulse IEC 61672 - 3 Class 1 (17)	Pass
Peak C Level 500Hz Negative Pulse IEC 61672 - 3 Class 1 (17)	Pass
Overload Indication IEC 61672 - 3 (18)	Pass
Octave and 1/3 Octave level IEC 61260 - 5.3	Pass

Calibrated on WCCL system type 9700

Measurements performed by: **Kent Zeng**

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 10382250B&K

West Caldwell Calibration Laboratories, Inc.
 uncompromised calibration
 1575 State Route 96, Victor NY 14564



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

Brüel & Kjær Microphone for Model No.: 4189 Serial No.: 2663088


Company: Hankard Environmental Inc. I. D. No.: XXXX

Calibration results:		Ambient Temperature: 21.8 °C	
Before & after data same: ...X...		Ambient Humidity: 30.8 % RH	
Combined Sensitivity @ 250 Hz and pressure of 100.46 kPa		Ambient Pressure: 100.458 kPa	
(Sens. with mic. and preamp.) 0 Volts Polarization voltage (External):		Calibration Date: 20-Apr-2016	
-26.60 dB re.1V/Pascal		Re-calibration Due: 20-Apr-2017	
46.77 mV/Pascal		Report Number: 26374 -3	
0.60 Ko (- dB re 50 mV/Pascal)		Control Number: 26374	
Sensitivity: Pass			
Freq. Response: Pass			
All tests: Pass			

The above listed instrument meets or exceeds the tested manufacturer's specifications.
 The IEC 651:1979 & 1993 Type 1 specification passed.

This Calibration is traceable through NIST test numbers: 683/284413-14
 The expanded uncertainty of calibration: 0.094dB at 95% confidence level with a coverage factor of k=2.

The pressure response recorded with electroacoustic method.



The above listed instrument was checked using calibration procedure documented in West Caldwell Calibration Laboratories Inc. procedure : **Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189B&K**
 Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NC SL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Measurements performed by: *[Signature]*
Kent Zeng

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189B&K

West Caldwell Calibration Laboratories, Inc.
 uncompromised calibration
 1575 State Route 96, Victor NY 14564



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

Brüel & Kjær Microphone for Model No.: 4189 Serial No.: 2663089


Company: Hankard Environmental Inc. I. D. No.: XXXX

Calibration results:		Ambient Temperature: 21.8 °C	
Before & after data same: ...X...		Ambient Humidity: 30.8 % RH	
Combined Sensitivity @ 250 Hz and pressure of 100.46 kPa		Ambient Pressure: 100.458 kPa	
(Sens. with mic. and preamp.) 0 Volts Polarization voltage (External):		Calibration Date: 20-Apr-2016	
-26.49 dB re.1V/Pascal		Re-calibration Due: 20-Apr-2017	
47.36 mV/Pascal		Report Number: 26374 -5	
0.49 Ko (- dB re 50 mV/Pascal)		Control Number: 26374	
Sensitivity: Pass			
Freq. Response: Pass			
All tests: Pass			

The above listed instrument meets or exceeds the tested manufacturer's specifications.
 The IEC 651:1979 & 1993 Type 1 specification passed.

This Calibration is traceable through NIST test numbers: 683/284413-14
 The expanded uncertainty of calibration: 0.094dB at 95% confidence level with a coverage factor of k=2.

The pressure response recorded with electroacoustic method.



The above listed instrument was checked using calibration procedure documented in West Caldwell Calibration Laboratories Inc. procedure : **Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189B&K**
 Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Measurements performed by: *[Signature]*
Kent Zeng

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189B&K

West Caldwell Calibration Laboratories, Inc.
 uncompromised calibration
 1575 State Route 96, Victor NY 14564



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

Brüel & Kjær Microphone for Model No.: 4952 Serial No.: 2653064

Company: Hankard Environmental Inc. I. D. No.: XXXX


Calibration results:		Before & after data same: ...X...		Ambient Temperature: 21.8 °C	
Combined Sensitivity @	250 Hz	and pressure of	100.46 kPa	Ambient Humidity:	30.8 % RH
(Sens. with mic. and preamp.)	0 Volts Polarization voltage (External):			Ambient Pressure:	100.458 kPa
	-30.15 dB re.1V/Pascal			Calibration Date:	20-Apr-2016
	31.08 mV/Pascal			Re-calibration Due:	20-Apr-2017
	4.15 Ko (- dB re 50 mV/Pascal)			Report Number:	26374 -9
Sensitivity:	Pass			Control Number:	26374
Freq. Response:	Pass				
All tests:	Pass				

The above listed instrument meets or exceeds the tested manufacturer's specifications.

This Calibration is traceable through NIST test numbers: 683/284413-14

The expanded uncertainty of calibration: 0.094dB at 95% confidence level with a coverage factor of k=2.

The pressure response recorded with electroacoustic method.



The above listed instrument was checked using calibration procedure documented in West Caldwell Calibration Laboratories Inc. procedure : Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4952B&K
 Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Measurements performed by: *[Signature]*
Kent Zeng

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4952B&K

West Caldwell Calibration Laboratories, Inc.
 uncompromised calibration
 1575 State Route 96, Victor NY 14564



Calibration Lab. Cert. # 1533.01

REPORT OF CALIBRATION

Brüel & Kjær Microphone for Model No.: 4952 Serial No.: 2653065

Company: Hankard Environmental Inc. I. D. No.: XXXX


Calibration results:		Before & after data same: ...X...		Ambient Temperature: 21.8 °C	
Combined Sensitivity @	250 Hz	and pressure of	100.46 kPa	Ambient Humidity:	30.8 % RH
(Sens. with mic. and preamp.)	0 Volts Polarization voltage (External):			Ambient Pressure:	100.458 kPa
	-30.94 dB re.1V/Pascal			Calibration Date:	20-Apr-2016
	28.39 mV/Pascal			Re-calibration Due:	20-Apr-2017
	4.94 Ko (- dB re 50 mV/Pascal)			Report Number:	26374 -8
Sensitivity:	Pass			Control Number:	26374
Freq. Response:	Pass				
All tests:	Pass				

The above listed instrument meets or exceeds the tested manufacturer's specifications.

This Calibration is traceable through NIST test numbers: 683/284413-14

The expanded uncertainty of calibration: 0.094dB at 95% confidence level with a coverage factor of k=2.

The pressure response recorded with electroacoustic method.



The above listed instrument was checked using calibration procedure documented in West Caldwell Calibration Laboratories Inc. procedure : Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4952B&K
 Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Measurements performed by: *[Signature]*
Kent Zeng

Calibrated on WCCL system type 9700


This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4952B&K


APPENDIX B

TURBINE POWER PRODUCTION DURING MEASUREMENTS


LWEP Operations at Location 2, March 29-30, 2016, 1st and 2nd Closest Turbines




LWEP Operations at Location 2, March 29-30, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 5, March 29-30, 2016, 1st and 2nd Closest Tubines




LWEP Operations at Location 5, March 29-30, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 2, March 31, 2016, 1st and 2nd Closest Turbines




LWEP Operations at Location 2, March 31, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 9, April 24, 2016, 1st and 2nd Closest Turbines




LWEP Operations at Location 9, April 24, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 10, April 24, 2016, 1st and 2nd Closest Turbines




LWEP Operations at Location 9, April 24, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 5, April 25, 2016, 1st and 2nd Closest Turbines




LWEP Operations at Location 5, April 25, 2016, 3rd and 4th Closest Turbines




LWEP Operations Location 10, April 25, 2016, 1st and 2nd Closest Tubines




LWEP Operations at Location 10, April 25, 2016, 3rd and 4th Closest Turbines




LWEP Operations Location 9, April 26, 2016, 1st and 2nd Closest Turbines




LWEP Operations at Location 9, April 26, 2016, 3rd and 4th Closest Locations




LWEP Operations at Location 10, April 26, 2016, 1st and 2nd Closet Turbines




LWEP Operations at Location 10, April 26, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 9, April 28, 2016, 1st and 2nd Closest Turbines




LWEP Operations at Location 9, April 28, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 10, April 28, 2016, 1st and 2nd Closest Turbines




LWEP - Operations Location 10, April 28, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 5, May23-24, 2016, 1st and 2nd Closest Turbines




LWEP Operations at Location 5, May 23-24, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 10, May 23-24, 2016, 1st and 2nd Closest Turbines




LWEP Operations at Location 10, May 23-24, 2016, 3rd and 4th Closest Turbines




LWEP Operations at Location 5, May 24, 2016, 1st and 2nd Closet Turbines




LWEP Operations at Location 5, May 24, 2016, 3rd and 4th Closest Turbines



LWEP Operations at Location 10, May24, 2016, 1st and 2nd Closest Turbines



LWEP Operations at Location 10, May 24, 2016, 3rd and 4th Closest Turbines



APPENDIX C

CALCULATION OF MAXIMUM TURBINE NOISE LEVEL AT LOCATION 2

TABLE C-1	Actual Power Output	Actual Hub-height Wind Speed	PWL at Hub-height Wind Speed	Maximum PWL	Actual to Maximum Delta
Turbine	(kw)	(m/s)	(dBA)	(dBA)	(dBA)
T6	1553	9.0	104.0	105.0	1.0
T15	969	8.0	102.0	105.0	3.0
T4	965	7.6	101.5	105.0	3.5
T18	1055	8.3	103.0	105.0	2.0
T14	1502	8.5	103.2	105.0	1.8
T19	1486	9.2	104.3	105.0	0.7

TABLE C-2	Actual PWL	Distance to Loc 2	Validation Correction	Distance Correction	Turbine Predicted Level
Turbine	(dBA)	(feet)	(dB)	(dB)	(dBA)
T6	104.0	1040	-4.9	-58	41
T15	102.0	1650	-4.9	-62	35
T4	101.5	2040	-4.9	-64	32
T18	103.0	2100	-4.9	-64	34
T14	103.2	2500	-4.9	-66	32
T19	104.3	3650	-4.9	-69	30
Total Predicted Level					43.4

TABLE C-3	Maximum PWL	Distance to Loc 2	Validation Correction	Distance Correction	Turbine Predicted Level
Turbine	(dBA)	(feet)	(dB)	(dB)	(dBA)
T6	105	1040	-4.9	-58	42
T15	105	1650	-4.9	-62	38
T4	105	2040	-4.9	-64	36
T18	105	2100	-4.9	-64	36
T14	105	2500	-4.9	-66	34
T19	105	3650	-4.9	-69	31
Total Predicted Level					45.1